




VALPARAISO FIRE DEPARTMENT

Bureau of Fire Prevention

PH: 219-462-8325
FAX: 219-531-8812

2605 Cumberland Dr.
Valparaiso, IN 46383

Occupant Name:	College of Court Reporting	InspectionType:	Reinspection #1 (Knox Box, Preplan, Annual)
Address:	455 Lincolnway	Inspection Date:	2/20/2023 (Initial Insp. Date: 2/9/2023)
Suite:	A		
City:	Valparaiso		
State:	IN		
Zip Code:	46383		
		Inspected By:	Mike Cervik mcervik@valpo.us

Insp. Result	Location	Code Set	Code
DEFICIENCY NOTED - Cleared	Floor 1	Indiana Fire Code 2014 Section 315 General Storage	315.3.3 - Equipment rooms.
 Deficiency cleared on 2/20/2023			

An inspection of the above property has been conducted. During this inspection, conditions affecting fire & life safety were noted to be in violation of the 2014 Indiana Fire Code, **675 IAC 22-2.5** Thank you for your cooperation in keeping your business and our community safe!

If you have any questions or concerns, please contact the inspector listed above by email.

Company Representative:


 Jeff Moody
 2/20/2023

Inspector:


 Mike Cervik

2/20/2023

Ref: 18548-18594